



Client: City of Rolling Meadows

Date: August 23, 2023

Project: Lead and Copper

PO #: 20230169

WorkOrder: 2308763

QC Level: LEVEL I

Temperature of samples upon receipt at SLI: C

Chain of Custody #:

General Comments:

- All results reported in wet weight unless otherwise indicated. (dry = Dry Weight)
- Sample results relate only to the analytes of interest tested and to sample as received by the laboratory.
- Environmental compliance sample results meet the requirements of 35 IAC Part 186 unless otherwise indicated.
- Waste water analysis follows the rules set forth in 40 CFR part 136 except where otherwise noted.
- Accreditation by the State of Illinois is not an endorsement or a guarantee of the validity of data generated.
- For more information about the laboratories' scope of accreditation, please contact us at (708) 544-3260 or the Agency at (217) 782-6455.
- All radiological results are reported to the 95% confidence level.

Abbreviations:

- Reporting Limit: The concentration at which an analyte can be routinely detected on a day to day basis, and which also meets regulatory and client needs.
- Quantitation Limit: The lowest concentration at which results can be accurately quantitated.
- J: The analyte was positively identified above our Method Detection Limit and is considered detectable and usable; however, the associated numerical value is the approximate concentration of the analyte in the sample.
- ATC: Automatic Temperature Correction. - TNTC: Too Numerous To Count
- TIC: Tentatively Identified Compound (GCMS library search identification, concentration estimated to nearest internal standard).
- SS: (Surrogate Standard): Quality control compound added to the sample by the lab.
- LA: Lab Accident - No valid data to report.
- VO: Insufficient Volume provided
- BR: Received broken
- IP: Invalid Sampling

Method References:

For a complete list of method references please contact us.

- E: USEPA Reference methods
- SW: USEPA, Test Methods for Evaluating Solid Waste (SW-846)
- M: Standard Methods for the Examination of Water and Wastewater
- USP: Latest version of United States Pharmacopeia

Workorder Specific Comments:



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A042

Matrix: DRINKING WATER

Lab ID: 2308763-001

Date Received: 08/08/2023 2:20 PM

Collection Date: 07/28/2023 6:10 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	40.0	0.596	1,300	J	µg/L	1	08/22/2023 11:25 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:25 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A002

Matrix: DRINKING WATER

Lab ID: 2308763-002

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 5:20 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	3.12	0.596	1,300	J	µg/L	1	08/22/2023 11:27 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:27 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A027

Matrix: DRINKING WATER

Lab ID: 2308763-003

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 6:00 PM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	52.5	0.596	1,300	J	µg/L	1	08/22/2023 11:29 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:29 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A026

Matrix: DRINKING WATER

Lab ID: 2308763-004

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/04/2023 7:00 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	6.79	0.596	1,300	J	µg/L	1	08/22/2023 11:31 PM	91846
Lead	0.775	0.755	15.0	J	µg/L	1	08/22/2023 11:31 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A022

Matrix: DRINKING WATER

Lab ID: 2308763-005

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 6:00 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	11.4	0.596	1,300	J	µg/L	1	08/22/2023 11:33 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:33 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A046

Matrix: DRINKING WATER

Lab ID: 2308763-006

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 7:38 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	8.38	0.596	1,300	J	µg/L	1	08/22/2023 11:34 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:34 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A034

Matrix: DRINKING WATER

Lab ID: 2308763-007

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/02/2023 7:15 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	12.2	0.596	1,300	J	µg/L	1	08/22/2023 11:36 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:36 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A032

Matrix: DRINKING WATER

Lab ID: 2308763-008

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 6:45 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	2.30	0.596	1,300	J	µg/L	1	08/22/2023 11:38 PM	91846
Lead	0.929	0.755	15.0	J	µg/L	1	08/22/2023 11:38 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A035

Matrix: DRINKING WATER

Lab ID: 2308763-009

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 5:50 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	22.1	0.596	1,300	J	µg/L	1	08/22/2023 11:42 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:42 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP2J060

Matrix: DRINKING WATER

Lab ID: 2308763-010

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 5:45 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	5.45	0.596	1,300	J	µg/L	1	08/22/2023 11:50 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:50 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A044

Matrix: DRINKING WATER

Lab ID: 2308763-011

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 5:15 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	69.8	0.596	1,300	J	µg/L	1	08/22/2023 11:52 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:52 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A029

Matrix: DRINKING WATER

Lab ID: 2308763-012

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 7:47 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	4.80	0.596	1,300	J	µg/L	1	08/22/2023 11:54 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:54 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A024

Matrix: DRINKING WATER

Lab ID: 2308763-013

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/02/2023 6:40 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	55.2	0.596	1,300	J	µg/L	1	08/22/2023 11:56 PM	91846
Lead	2.16	0.755	15.0	J	µg/L	1	08/22/2023 11:56 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A030

Matrix: DRINKING WATER

Lab ID: 2308763-014

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 6:30 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	6.63	0.596	1,300	J	µg/L	1	08/22/2023 11:58 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:58 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A010

Matrix: DRINKING WATER

Lab ID: 2308763-015

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 6:10 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	73.7	0.596	1,300	J	µg/L	1	08/22/2023 11:59 PM	91846
Lead	ND	0.755	15.0		µg/L	1	08/22/2023 11:59 PM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A019

Matrix: DRINKING WATER

Lab ID: 2308763-016

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 6:30 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	24.2	0.596	1,300	J	µg/L	1	08/23/2023 12:01 AM	91846
Lead	1.13	0.755	15.0	J	µg/L	1	08/23/2023 12:01 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A021

Matrix: DRINKING WATER

Lab ID: 2308763-017

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 7:54 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	11.5	0.596	1,300	J	µg/L	1	08/23/2023 12:03 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:03 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A013

Matrix: DRINKING WATER

Lab ID: 2308763-018

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/02/2023 5:31 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	17.2	0.596	1,300	J	µg/L	1	08/23/2023 12:05 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:05 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A003

Matrix: DRINKING WATER

Lab ID: 2308763-019

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 6:15 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	62.5	0.596	1,300	J	µg/L	1	08/23/2023 12:17 AM	91846
Lead	0.761	0.755	15.0	J	µg/L	1	08/23/2023 12:17 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A005

Matrix: DRINKING WATER

Lab ID: 2308763-020

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/02/2023 9:35 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	9.81	0.596	1,300	J	µg/L	1	08/23/2023 12:19 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:19 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A004

Matrix: DRINKING WATER

Lab ID: 2308763-021

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/02/2023 12:05 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	4.93	0.596	1,300	J	µg/L	1	08/23/2023 12:21 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:21 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A008

Matrix: DRINKING WATER

Lab ID: 2308763-022

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/03/2023 6:28 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	4.69	0.596	1,300	J	µg/L	1	08/23/2023 12:22 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:22 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A031

Matrix: DRINKING WATER

Lab ID: 2308763-023

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/01/2023 10:30 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	32.2	0.596	1,300	J	µg/L	1	08/23/2023 12:24 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:24 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A048

Matrix: DRINKING WATER

Lab ID: 2308763-024

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/04/2023 3:50 PM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	29.6	0.596	1,300	J	µg/L	1	08/23/2023 12:26 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:26 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 23, 2023

Project Name: Lead and Copper

Workorder: 2308763

Client Sample ID: LP1A045

Matrix: DRINKING WATER

Lab ID: 2308763-025

Date Received: 08/08/2023 2:20 PM

Collection Date: 08/08/2023 5:25 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	9.95	0.596	1,300	J	µg/L	1	08/23/2023 12:28 AM	91846
Lead	ND	0.755	15.0		µg/L	1	08/23/2023 12:28 AM	91846



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 30, 2023

Project Name: Lead and Copper

Workorder: 2308C92

Client Sample ID: LP1A020

Matrix: DRINKING WATER

Lab ID: 2308C92-001

Date Received: 08/14/2023 4:15 PM

Collection Date: 08/10/2023 6:05 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	43.9	0.596	1,300	J	µg/L	1	08/28/2023 11:58 PM	91952
Lead	ND	0.755	15.0		µg/L	1	08/28/2023 11:58 PM	91952



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 30, 2023

Project Name: Lead and Copper

Workorder: 2308C92

Client Sample ID: LP1A001

Matrix: DRINKING WATER

Lab ID: 2308C92-002

Date Received: 08/14/2023 4:15 PM

Collection Date: 08/10/2023 4:30 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
METALS BY ICPMS			Method: EPA-200.8-Rev 5.4, 1994			Analyst: JSM		
Copper	7.88	0.596	1,300	J	µg/L	1	08/29/2023 12:02 AM	91952
Lead	ND	0.755	15.0		µg/L	1	08/29/2023 12:02 AM	91952



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 30, 2023

Project Name: Lead and Copper

Workorder: 2308C92

Client Sample ID: LP2J053

Matrix: DRINKING WATER

Lab ID: 2308C92-003

Date Received: 08/14/2023 4:15 PM

Collection Date: 08/10/2023 7:40 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
-----------	--------	--------------	-----	-------	-------	-----------------	---------------	----------

METALS BY ICPMS

Method: EPA-200.8-Rev 5.4, 1994

Analyst: JSM

Copper	14.1	0.596	1,300	J	µg/L	1	08/29/2023 12:04 AM	91952
Lead	ND	0.755	15.0		µg/L	1	08/29/2023 12:04 AM	91952



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 30, 2023

Project Name: Lead and Copper

Workorder: 2308C92

Client Sample ID: LP1A025

Matrix: DRINKING WATER

Lab ID: 2308C92-004

Date Received: 08/14/2023 4:15 PM

Collection Date: 08/09/2023 6:00 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
-----------	--------	--------------	-----	-------	-------	-----------------	---------------	----------

METALS BY ICPMS

Method: EPA-200.8-Rev 5.4, 1994

Analyst: JSM

Copper	6.79	0.596	1,300	J	µg/L	1	08/29/2023 12:11 AM	91952
Lead	3.38	0.755	15.0	J	µg/L	1	08/29/2023 12:11 AM	91952



Suburban Laboratories, Inc.

1950 S. Batavia Ave., Suite 150, Geneva, IL 60134 (708) 544-3260

Laboratory Results

Client ID: City of Rolling Meadows

Report Date: August 30, 2023

Project Name: Lead and Copper

Workorder: 2308C92

Client Sample ID: LP1A015

Matrix: DRINKING WATER

Lab ID: 2308C92-005

Date Received: 08/14/2023 4:15 PM

Collection Date: 08/09/2023 6:35 AM

Parameter	Result	Report Limit	MCL	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
-----------	--------	--------------	-----	-------	-------	-----------------	---------------	----------

METALS BY ICPMS

Method: EPA-200.8-Rev 5.4, 1994

Analyst: JSM

Copper	4.43	0.596	1,300	J	µg/L	1	08/29/2023 12:13 AM	91952
Lead	ND	0.755	15.0		µg/L	1	08/29/2023 12:13 AM	91952